

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Poly Crystalline Silicon Terrestrial Photovoltaic Module

Name and address of the applicant

Aplicaciones Técnicas de la Energía SL
Pol. Ind. Juan Carlos I, Avda de la Foia 14, 46440 Almussafes, Valencia,
Spain

Name and address of the manufacturer

Waaree Energies Limited
Plot No. 231-236, Surat Special Economic Zone, Diamond Park, Sachin,
Surat – 394230, Gujarat, India

Name and address of the factory

Note: When more than one factory, please report on page 2

Waaree Energies Limited
Plot No. 231-236, Surat Special Economic Zone, Diamond Park, Sachin,
Surat – 394230, Gujarat, India

Ratings and principal characteristics

System voltage 1000V, Class of application A, Class II, Fire resistance
Class C, Maximum over-current protection rating 15A

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

A-xxxP GSE
(xxx is the number of 335, 330, 325, 320, 315, 310, 305, 300, 295,
290, 285, 280, 275, 270, 265, 260, 255, 250, 245, 240, 150, 145,
140, 135, 130, 125)
xxx means rated maximum output power

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 61215:2005
IEC 61730-1:2004 + A1:2011 + A2:2013
IEC 61730-2:2004 + A1:2011

As shown in the Test Report Ref. No. which forms part of this Certificate

160302037SHA-001, 160302037SHA-002, 160302037SHA-003

This CB Test Certificate is issued by the National Certification Body

Intertek Testing Services (Singapore) Pte Ltd
5, Pereira Road, #06-01
Asiawide Industrial Building
Singapore 368025

Date: 18 April 2017

Signature:


Ong Keng Chuan